

Project Name:	
Project Address:	Date:
Designer of Record:	Telephone:
Contact Person:	Telephone:
City:	

## Mandatory Provisions Checklist

- Automatic lighting shutoff controls are provided based on either a scheduling device or an occupant sensor
  - Exception: Space is intended for 24-hour operation
  - Exception: Space is smaller than 5000 ft<sup>2</sup>
- Each space enclosed by ceiling-height partitions has an independent, accessible control that operates general lighting in the space
  - Exception: The control is located in a remote location for safety or security reasons
- For spaces less than or equal to 10,000 ft<sup>2</sup>, a separate space control is provided for each 2500 ft<sup>2</sup> of area
- For spaces more than 10,000 ft<sup>2</sup>, a separate space control is provided for each 10,000 ft<sup>2</sup> of area
- Either a photosensor or an astronomical time switch controls exterior lighting applications
  - Exception: Lights must remain on for safety, security or eye adaptation reasons
- Two-lamp tandem-wired ballasts
- Display lighting has a separate control
- Case lighting has a separate control
- Hotel/motel guest rooms have a master switch at the main entry
- Task lighting has a separate control
- Nonvisual lighting has a separate control
- Demonstration lighting has a separate control
- Exit signs larger than 20 W have an efficacy greater than or equal to 35 lumens/W
- Exterior luminaires greater than 100 W have lamps with minimum efficacy of 60 lumens/W
  - Exception: Luminaire is activated with a motion sensor

## Interior Lighting Power Allowance (Building Area Method)

Building Type	Lighting Power Density (W/ft <sup>2</sup> )	Building Area (ft <sup>2</sup> )	Lighting Power Allowance (W)
Total			

## Interior Lighting Power Allowance (Space-by-Space Method)

Building Type	Common/Specific Space Type	Lighting Power Density (W/ft <sup>2</sup> )	Space Area (ft <sup>2</sup> )	Lighting Power Allowance (W)
Total				





